

STATE OF NEBRASKA  
DEPARTMENT OF ROADS  
ADDENDUM NO. 2  
AND  
ELECTRONIC BIDDING SYSTEM  
AMENDMENT NO. 2  
PROJECT NO. S-6-2(1025)  
CONTROL NO.70629A  
CALL ORDER N17  
ON US-6, W 4<sup>TH</sup> ST – E 7<sup>TH</sup> ST., MCCOOK  
LETTING DATE: NOVEMBER 14, 2002

The Schedule of Items for Group 3 is amended as follows:

1. The quantity for the bid item "600 mm White Preformed Pavement Marking, Type 3, Grooved" is incorrect. The quantity should read 290.000 m. (This bid item was added in Addendum No. 1 / Amendment No. 1 with an incorrect quantity.)

The Schedule of Items for Group 4A is amended as follows:

1. The bid item "250 mm Insertable Valve" has been added with a quantity of 2.000 Each.

The EBS generated bid item sheets must show this correction or the bid will be considered void.

\* \* \* \* \*

On page 40 of the Special Provisions, paragraph II.B., "Ductile Iron Fittings", is amended to include the following:

Method of Measurement will be based on cast iron weights as per AWWA C110 or the latest revision thereof.

\* \* \* \* \*

On page 41 of the Special Provisions, paragraph II.E. is void and superseded by the following:

At all locations requiring new standard size service taps into the new main, the Contractor shall install 25 mm brass Ford Corporation stop with a Ford FS101 saddle. All new service lines shall be Eagle Pure-Core, 200 psi rated 25 mm or larger polyethylene pipe. The service shall also include a new Ford ball valve curb stop box as shown on the plans.

Where sizes 30 mm or larger are required, the Contractor shall install a brass Ford Corporation stop with a Ford FS202 saddle. Service lines shall be Eagle Pure-Core, 200 psi rated polyethylene pipe of the size indicated on the plans. The service shall also include a new Ford ball valve curb stop and curb box as shown on the plans.

\* \* \* \* \*

On pages 40 and 41 of the Special Provisions, Section II., "Material", is amended to include the following:

F. Insertable Valves

Insertable valves shall be Insta-Valve by Hydra-Stop, or approved equivalent, permanent insertable gate valve, sized to the main. Insertable valves shall be installed into the pressurized main without disruption of service.

The Nebraska supplier for Insta-Valve is Municipal Supply of Hastings, (800) 395-7473.

\* \* \* \* \*

Upon execution of the contract, the plans will be revised to reflect these changes.

DEPARTMENT OF ROADS

Claude Oie  
Construction Engineer

Issued: November 4, 2002

CO: N17AD211

NOTICE: Only the contractors issued bidding proposals receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the contractor.