

STATE OF NEBRASKA
DEPARTMENT OF ROADS
ADDENDUM NO. 1
PROJECT NO. BRO-7022(11)
CONTROL NO. 31216
CALL ORDER F10
ON A COUNTY ROAD SOUTH OF HOMER
LETTING DATE: MARCH 4, 2004

On plan sheet 10, the SOLE PLATE detail is amended to include the following note:

NOTE: Sole plate thickness = 40 mm.

* * * * *

On plan sheet 13, the NOTE column (upper right of sheet) is amended to include the following:

Rebar Clearance in Deck
Top of Deck = 65 mm
Bottom of Deck = 25 mm

* * * * *

Upon execution of the contract, the plans will be revised to reflect these changes.

DEPARTMENT OF ROADS



Claude Oie
Construction Engineer

Issued: February 25, 2004

CO:AH:F10AD103

NOTICE: Only the contractors issued bidding proposals receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the contractor.