

STATE OF NEBRASKA
DEPARTMENT OF ROADS
ADDENDUM NO. 2
AND
ELECTRONIC BIDDING SYSTEM
AMENDMENT NO. 2
PROJECT NO. BR-275-7(187)
CONTROL NO. 21574D
CALL ORDER 215
US-275, SOUTH OMAHA BRIDGE,
IOWA BRIDGE APPROACH
LETTING DATE: SEPTEMBER 13, 2007

The Schedule of Items is amended as follows:

1. In Group 6, the bid item "Steel Expansion Diaphragm" has been added with a quantity of 35.000 EACH.
2. In Group 6A, the bid item "Steel Expansion Diaphragm" has been added with a quantity of 35.000 EACH.

The EBS generated bid items sheets must show this correction or the bid will be considered void.

* * * * *

On plan sheet 14, the Group 6 Quantities are amended to include the following:

Steel Expansion Diaphragm 35.000 EACH

* * * * *

On plan sheet 15, the Group 6A Quantities are amended to include the following:

Steel Expansion Diaphragm 35.000 EACH

* * * * *

Plan sheet 120 is amended as follows:

1. The third note in the "Intermediate Diaphragm at Midspan" detail is void and superseded by the following:

Payment for diaphragm at midspan shall be the bid item STEEL DIAPHRAGM (EACH). Payment for diaphragm at expansion joint shall be the bid item STEEL EXPANSION DIAPHRAGM (EACH). All miscellaneous items required for installation of intermediate and expansion joint diaphragms shall be subsidiary to the their respective bid item.

2. The "End Diaphragm At Expansion Joint" detail is amended to include the following note:

The Contactor shall have the following options to construct the diagonal members of the End Diaphragm in order to match the slope of the slab:

1. Shop weld the diagonal angles to the MC 10x25 member and field weld the diagonal members to the L 6"x6" angles and field dress these welds with galvanized paint.
2. The diagonal angles may be bolted, both top and bottom, using 7/8" Φ H.S. bolts at 3" centers.

* * * * *

On plan sheets 158 and 334, the NOTE in the "Drain Trench Grate Details" is amended to read:

The grate detail, Section D-D, may be either the vane grate, as shown, or a rectangular grate opening.

* * * * *

Upon execution of the contract, the plans will be revised to reflect these changes.

DEPARTMENT OF ROADS



Claude Oie
Construction Engineer

Issued: September 10, 2007

CO:215AD209

NOTICE: Only the contractors issued bidding proposals receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the contractor.