Materials Sampling Guide

Table of Contents

Section 4

Asphaltic Concrete Materials

1.	Mineral Aggregate (Gravel, Sand, Sand-Gravel)	Page 4-1
2.	Mineral Aggregate (Crushed Rock)	Page 4-1
	Crushed Rock (Screenings, Man-Sand)	
	Quartzite and Granite	
5.	Quartzite, Chat and Granite (Screenings, Man-Sand)	Page 4-1
6.	Crushed Mineral Aggregate or Chat for Microsurfacing	Page 4-2
	Mineral Filler	

Date: 08-23-00 Revised: 03-30-04

	TYPE OF TEST	Minimum Materia	l Certificate, Sample	and Inspection	Requirements					
MATERIAL		Q.C. SAMPLING AND TESTING BY CONTRACTOR	VERIFICATION SAMPLING AND TESTING BY NDOR			LOCATION OF ADDITIONAL INFORMATION				
Section: 4 –	Asphaltic Cor	ncrete Materials	FIELD PERSONNEL	BRANCH LAB	LINCOLN LAB	NOTE No.	PAGE No.			
1) Mineral Aggregate (Gravel, Sand, Sand- Gravel)	Quality		Project personnel will supply the 60 pound sample needed to perform the testing shown under the Lincoln Lab column. The sample shall be taken at the project stockpile.		One 60 pound sample for quality tests for source approval, if so designated on the "Source of Aggregates To Be Used" form or when changes in quality or characteristics occur. No other samples for quality or correlation are needed.	4	4			
2) Mineral Aggregate (Crushed Rock)	Quality		Project personnel will supply the 60 pound sample needed to perform the testing shown under the Lincoln Lab column. The sample shall be taken at the project stockpile.		One 60 pound sample for quality tests for 3000 tons of aggregate used or fraction thereof.	5	4			
3) Crushed Rock (Screenings, Man-Sand)	Quality		Project personnel will supply the 10 pound sample needed to perform the testing shown under the Lincoln Lab column. The sample shall be taken at the project stockpile.		One 10 pound sample for quality tests for each 5000 tons of aggregate used or fraction thereof.	5	4			
4) Quartzite & Granite	Quality		Project personnel will supply the 60 pound sample needed to perform the testing shown under the Lincoln Lab column. The sample shall be taken at the project stockpile.		One 60 pound sample for quality tests each 5000 tons of aggregate used or fraction thereof.					
5) Quartzite, Chat & Granite (Screenings, Man-Sand)	Quality		Project personnel will supply the 10 pound sample needed to perform the testing shown under the Lincoln Lab column. The sample shall be taken at the project stockpile.		One 10 pound sample for quality tests for each 5000 tons of aggregate used or fraction thereof.					

	Minimum Material Certificate, Sample and Inspection Requirements								
MATERIAL	TYPE OF TEST	Q.C. SAMPLING AND TESTING BY CONTRACTOR	VERIFICATION SAMPLING AND TESTING BY NDOR			LOCATION OF ADDITIONAL INFORMATION			
Section: 4 –	Asphaltic Cor	crete Materials (continued)	FIELD PERSONNEL	BRANCH LAB	LINCOLN LAB	NOTE No.	PAGE No.		
6) Crushed Mineral Aggregate or Chat for Micro- surfacing	Quality & Gradation, FAA, L.A. & Sand Equivalent		One sample for gradations every 650 tons of material used or fraction thereof. The sample shall be taken at the project.		One 60 pound sample for first 1000 tons of aggregate used. Subsequent samples will be one 10 pound sample for each 1000 tons used, or fraction thereof. (Duplicate of sample tested in the field).	4	4		
7) Mineral Filler	Plasticity Index & Gradation		Project personnel will supply the 10 pound sample needed to perform the testing shown under the Lincoln Lab column. The sample shall be taken at the project.		One 10 pound sample per project at production for gradation and plasticity index, unless changes in quality or characteristics occur.				