

SECTION 1041 -- DRAIN TILE

1041.01 -- Description

1. Clay drain tile shall conform to the Type II, "Extra-Quality Drain Tile" requirements of AASHTO M 179.
2. Concrete drain tile shall conform to the "Extra-Quality Drain Tile" requirements of AASHTO M 178.

1041.02 -- Acceptance Requirements

Drain tile will be accepted based on requirements of this Section and sampling and testing requirements in accordance with the NDR *Materials Sampling Guide*.

SECTION 1042 -- STRUCTURAL PLATE PIPE

1042.01 -- Description

1. Galvanized steel structural plate for pipe, pipe-arches, and arches shall conform to the requirements of AASHTO M 167, with the exception that units on which the spelter coating has been damaged shall be repaired in accordance with Section 1061.
2. Aluminum alloy structural plate for pipe, pipe-arches, and arches shall conform to the requirements of AASHTO M 219.

1042.02 -- Acceptance Requirements

Structural pipe plate will be accepted based on requirements of this Section and sampling and testing requirements in accordance with the NDR *Materials Sampling Guide*.